

Prescriptive Insulation & Window Requirements

2009 IECC

Climate Zone	Fenestration U-factor	Skylight U-Factor	SHGC	Ceiling R-Value	Wood Frame Wall R-Value	Mass Wall R-Value	Floor R-Value	Basement Wall R-Value	Slab R-Value & Depth	Crawl Space Wall R-Value
4	0.35	0.60	NR	38	13	5/10	19	10/13	10, 2ft	10/13
5	0.35	0.60	NR	38	20 or 13+5	13/17	30	10/13	10, 2ft	10/13
6	0.35	0.60	NR	49	20 or 13+5	15/19	30	15/19	10, 4ft	10/13

2015 IECC

Climate Zone	Fenestration U-factor	Skylight U-Factor	SHGC	Ceiling R-Value	Wood Frame Wall R-Value	Mass Wall R-Value	Floor R-Value	Basement Wall R-Value	Slab R-Value & Depth	Crawl Space Wall R-Value
4	0.35	0.55	0.40	49	20 or 13+5	8/13	19	10/13	10, 2ft	10/13
5	0.32	0.55	NR	49	20 or 13+5	13/17	30	15/19	10, 2ft	15/19
6	0.32	0.55	NR	49	20 or 13+5	15/20	30	15/19	10, 4ft	15/19

Shows Increase in Stringency Over Previous Code